


Manual for certification of sludge

2.6 Control of flow meter

Municipality of Höganäs

2013

 HÖGANÄS KOMMUN SAMHÄLLSBYGGNADSFÖRVALTNINGEN	Manual for certification of sludge	Revised:	2012-02-14
		Editon:	1.6
2.6. Control of flow meter		Approved by:	Fredrik Arthursson
		Established by:	Thomas Almenberg
		Page:	1(1)

1. Purpose

Checks must be made to ensure that the function of the outgoing flow meter is flawless.



Part-financed by the European Union
(European Regional Development Fund)

2. Range

The routine includes checking and reading of outgoing flow meter. Outgoing flow meter is used for reporting in Revaqsystemet.

3. Supervisor

VA-manager is responsible for the routine. Operational staff is responsible for the performance of control

4. Instruction

The flow meters shall be visually checked for any eventual alarm; measurements on the respective flow meter shall be recorded daily and compared with each other. At tangible difference in measured cubic number of flow meters further control shall be performed.

5. Documentation

Documented in the operating record \\hoganäs\file\VA-avdelningen\Reningsverket\Driftjournaler ARV\Driftjournal2012

Latest edition of this document is stored in the binder "Manual för certifiering av avloppsslam".

Pathway for digital file: C:\Users\Ayumi Nakamura\Desktop\Collected and Categorized Euroslam Documents\Levererade dokument Euroslam\Component 3\Self Monitoring Manuals\Self Monitoring Manual Höganäs englisb\2.6_Kontroll av flödesmätare.docx